

Office of the Executive Engineer
Public Health Engineering Department, Sasaram (Rohatas)

Divisional Laboratory:- Sasaram

(Values In mg /Lit. except pH. Otherwise mentioned)

Zone :- Patna		Division Name: SASARAM										Date:-28/02/2026					
Sl. No.	Block	Panchayat	Village	Location of Source	Parameters												
					pH	Turb	Ec	TDS	TH	Ca	Mg	Cl	Alka.	Fe	No3	So4	F
1	Dehri	R.S.K.Public School Bastipur,Dehri	R.S.K.Public School Bastipur,Dehri	7.26	1	934	607	386	64	54.92	84	300	0.1	BDL	40	0.250	Negative
Desirable Limit				6.5-8.5	1	-	500	200	75.0	30.00	250	200	1	45	200	1	
Drinking Water Specification (Second Revision) IS 10500 /2012				NR	5.0 NTU		2000	600	200	100	1000	600	NR	NR	400	1.5	
Permissible limit in absence of alternate source																	

Note:- Sample collected By - J.E. Sasaram
 BDL- Below detection limit


 28/02/2026
 Chemist
 P.H.Division.Sasaram


 28/02/2026
 Executive Engineer
 P.H.Division.Sasaram